

## Cascades East Transit

Central Oregon Intergovernmental Council  
334 NE Hawthorne Ave, Bend, OR 97701  
cascadeseasttransit.com



# COIC

## Invitation for Bids CET 23-05: COIC Hawthorne Station Parking Lot Redesign

### Addendum 1: Responses to Vendor Submitted Question

**Prepared by:** Kimberly Banner, Executive Coordinator

**Date:** October 18, 2023

### Notice

The deadline for questions/Requests For Information from vendors is open until **Monday October 23rd, 2023, at 5pm PDT** to allow time to consider the responses in this addendum.

COIC's deadline for vendors to submit complete proposals remains **October 31st, 2023 at 5pm PDT**.

---

Questions were submitted to the Central Oregon Intergovernmental Council (COIC) / Cascades East Transit (CET) from TOMCO Electric. Below is the questions and the responses.

Regarding the enclosures that are called for on ME4.0 and ME4.1. Plan sheets are calling for a 86"Hx112"Wx20"D Nema 12X free standing stainless steel enclosure with pad, Hoffman A86M series or approved equal. We have multiple issues that need addressed;

The Hoffman A86M series is a floor standing multi door Nema12X mild steel enclosure that is not available in stainless steel.

**Correction - Material should be NEMA 3R min. rated, painted finish.**

The Hoffman A86M series is a floor standing multi door enclosure that is not available with floor stands as depicted on ME4.0 and MA4.1, presumably specified to prevent snow/water intrusion.

---

**Clarification – per cut sheet, stands are an available accessory. We spoke with manufacturer and they confirmed it was acceptable, however they recommend four (4) stands instead of two (2). See also attached email for sketch and clarification from manufacturer.**