

Cascades East Transit

Central Oregon Intergovernmental Council
334 NE Hawthorne Ave, Bend, OR 97701
cascadeseasttransit.com



COIC

Invitation for Bids CET 23-05: COIC Hawthorne Station Parking Lot Redesign

Addendum 2: Responses to Vendor Submitted Question

Prepared by: Kimberly Banner, Executive Coordinator

Date: October 30, 2023

Notice

COIC's deadline for vendors to submit complete proposals remains **October 31st, 2023 at 5pm PDT.**

Question: Please clarify Concrete curb Height. Bid Item 23 calls for a 16" curb , but the plans reference a 12" curb .

Answer: The plans are correct and the typo is the bid schedule. The correct curb height should be 12".
